| ID facilityName | assessmentDate vvlAssessmentType | leadAssessor | vvlLeadAssessorAffiliation | vvlCurrentStatus | vvlDamageLevel | criticalDamage | comments *1 million gal elevated storage? |
|---|--|---------------------------------------|----------------------------|------------------|----------------|----------------|--|
| 1700638 MONTGOMERY TRACE WATER SYSTEM | 42:44.0 OnSite Visit | Kathleen Campbell | TCEQ | ОК | None | NO | *chlorine gas2 *20 days worth of disinfectant |
| | | | | | | | 3. The backup generator ran Friday 9:30- 11:00 pm. 8. Seven total left stations- lost two pumps will be replaced this week. Backup pumps at each station. |
| 10158001 CITY OF DANBURY - CITY OF DANBURY CENTRAL WWTP | 56:55.0 OnSite Visit | Jack Coleman | TCEQ | Рор | None | NO | There were two backup pumps running in two of the left stations. Overall the plant was operable. 2. Unknown - looks intact 3. Reported Flooding |
| | | | | | | | 4. Unknown 2 |
| | | | | | | | Reported on 9/2/2017 that they had issued a BWN but were operational. 2 10. Unknown 2 16. Unknown 2 |
| 1610017 TRES PALACIOS OAKS SUBDIVISION | 19:39.0 OnSite Visit | Faith Cotton | TCEQ | RESULTS | | | The city has two lift stations. One is currently online with a generator, the other is not functional. |
| 11117001 CITY OF AUSTWELL - CITY OF AUSTWELL WWTP | 29:28.0 OnSite Visit | Eric Lindgren | TCEQ | OPGen | Medium | NO | The city is using a Vac truck since it is not able to pump. |
| 13609001 ALDINE ISD - ALDINE ISD ANNE LOUISE EDUCATIONAL COMPLEX | 30:15.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Fully operational. No follow up needed. Information Unknown. |
| 1011687 ATASCOCITA ACRES SUBDIVISION | 14:00.0 OnSite Visit | Nicole Reed | TCEQ | OUT | | | 4. Very little flow which why there was no discharge. 2 8. 1 onsite collectino system at the lift station. 120 connections total. 2 There were bottles of Chlorine gas. 4 150 lb bottles. They use 2 lbs per day, so should be able to |
| 14641001 2006 MUSTANG CREEK DEVELOPMENT INC - 2006 MUSTANG CREEK DEVELOPMENT WWTP | 46:49.0 OnSite Visit | Jack Coleman | TCEQ | ОК | None | NO | last 75 days. Fences down that share border with homes in neighborhood. Gate open and utility trucks present but nobody at plant. Unknown if down fencing caused by sotrm damage. Damage to |
| 1013354 HARRIS COUNTY MUD 412 | 15:46.0 OnSite Visit | Nicole Reed | TCEQ | ОК | Minor | YES | equipment not observed Torando damage. 16. & 17. By phone: |
| 200010 CITY OF WEST COLUMBIA | 45:49.0 OnSite Visit | Josephine Garcia | TCEQ | SITE | None | UNKNOWN | |
| 290027 PORT ALTO HOA DISTRICT 1 1700032 PATTON VILLAGE WEST WATER SYSTEM | 37:44.0 OnSite Visit 40:06.0 OnSite Visit | Chris Caudle Josephine Garcia | TCEQ TCEQ | INOP OK | None | NO NO | |
| 1011995 BAYOU FOREST VILLAGE MOBILE HOME PARK | 34:28.0 OnSite Visit | Nicole Reed | TCEQ | OK | None | NO | |
| 2050015 CITY OF ARANSAS PASS | 45:42.0 OnSite Visit | Eric Lindgren | TCEQ | INOP | Severe | YES | Elevated storage tank collapsed. Will not start distributing water again until collection system is back up and running and sewage plant can handle flow. |
| | | | | | | | Operating company (Texas Rain) difficult to get ahold of and owners (out of state) have very little information. According to customers of the water system, the power has been restored and water is being delivered. The system has been under a BWN since before the storm, and it is unclear if an operator has been onsite since the power has been restored. One customer of the |
| 2350036 COLETO WATER | 37:52.0 OnSite Visit | Danny Pritchard | TCEQ | LP/LT | Minor | NO | water system states he is a licensed operator and tested the chlorine in the water with a colorimeter to be above 11.0 mg/L. |
| 14210001 KAMPGROUNDS OF AMERICA INC - LAKE CONROE KOA WWTP 11807001 FOREST HILLS MUD - FOREST HILLS MUD WWTP | 00:17.0 OnSite Visit 05:16.0 OnSite Visit | Rudy Molina Rudy Molina | EPA EPA | OK OK | None None | NO NO | When were you last out there? a day or two ago, according to Patty (manager) with KOA. Last onsite date is unknown. |
| | | | | | | | 400,000 gallon elevated water storage tank at 903 Palmetto is structurally damaged. All upper tier cross-bracing of the tower's six legs has been compromised. The TxSG assessment team recommended that the 50-year old tank be drained to reduce risk of structural failure. Mr. Smith concurred with this recommendation and indicated the tank would be drained within 24 hours. Extensive corrosion of structural steel contributed to this situation. Taking this tank off-line will |
| 40002 CITY OF ROCKPORT | 38:54.0 OnSite Visit | Fred Waterman, TXSG | TCEQ | GENLP | Severe | YES | not effect pressure. BWN verbally told to customers as their meters were turned on. Minor distribution system |
| 1960007 TOWN OF BAYSIDE | 48:40.0 OnSite Visit | Eric Lindgren | TCEQ | GENLP | Minor | NO | damage. |
| 360081 LEANING OAKS WATER ASSOCIATION | 37:04.0 OnSite Visit | Michele Risko | TCEQ | RESULTS | | NO | 9/2/17 email shows plant checked and operational. System still on BWN. PWS is without power. They used an auto dialer system to issue a BWN. Unsure if storage was |
| 2470020 LAKE VALLEY WATER | 24:47.0 OnSite Visit | Jacolyn Saldana | TCEQ | INOP | None | NO | enough to maintain pressure. A generator is scheduled for delivery this afternoon. The plant is on site but is not setup yet. The is not an actiive permit. They are several months |
| 15393001 LIGHTHOUSE RV PARK, LLC - LIGHTHOUSE RV PARK WWTP | 05:49.0 OnSite Visit | Louis Herrin | TCEQ | ОК | None | UNKNOWN | away from starting this plant up. |
| 12206001 NORTH GREEN MUD - NORTH GREEN MUD WWTP | 56:35.0 OnSite Visit | Dustin Roberts | TCEQ | OK | None | NO | Heard aeration, water and blowers. Was unable to access and make contact. Hypochlorination |
| 1700730 MAGNOLIA COUNTRY RV PARK 12617001 HOUSTON METRO RV PARK INC - KOA HOUSTON CENTRAL WWTP | 20:36.0 OnSite Visit | Kathleen Campbell | TCEQ | OK OK | None None | NO NO | 4% not stored onsite, supplied by operator, 60 days worth. |
| 12617001 HOUSTON WETRO RV PARK INC - KOA HOUSTON CENTRAL WWTP | 50:38.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | | Fully operational. No follow-up needed. Other POC phone numbers are 281-734-5485. 2 10. Current collection system operational status is unknown. 2 No electronics are working. Someone was at the facility on the first. They have chlorine. Currently |
| 11930001 LAZV BIVER INARROVENACNIT DISTRICT LAZV BIVER INARROVENACNIT DISTRICT MUNTE | E0.28 0 0x5tz Vicit | Nicholo Batista Nussa | TCEO | OK | None | | not discharging water. The right one going is discharging, however. Did have an overflow. Might |
| 11820001 LAZY RIVER IMPROVEMENT DISTRICT - LAZY RIVER IMPROVEMENT DISTRICT WWTP 290028 PORT ALTO WSC | 50:38.0 OnSite Visit 46:27.0 OnSite Visit | Nichole Batista Nunes Chris Caudle | TCEQ TCEQ | OK INOP | None None | NO NO | be on the grid. |
| 2350055 KEY ROAD SUBDIVISION WATER SYSTEM | 55:01.0 OnSite Visit | Karla Treviño | TCEQ | LP/LT | | | The facility purchases water from Victoria Co. WCID No. 1 6. 20 psi on pressure tank. 16. ASAR |
| 200181 CHAPLINES MOBILE HOME PARK | 15:46.0 OnSite Visit | Josephine Garcia | TCEQ | LP/LT | None | NO | 16. ASAP ② Unit 1 - CI- free 0.01 mg/L 30psi 4. Unknown② |
| 2360052 WALKER COUNTY SUD C | 50:44.0 OnSite Visit | Destiny Geppert | TCEQ | UNKNOWN | None | NO | 10. Unknown ? |
| 450052 CARDON VILLA MOBILE HOME PARK | 23:50.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Chemical shortages Hypochlorination Poly for sequestration |
| | 25.55.5 Stidite Vidit | | | | | | ·, · σσημοσούστου |

| | | | | | | | 10. Unknown |
|---|-----------------------|-----------------------|-------|---------|----------------------|---------|---|
| | | | | | | | 11 & 12 Unknown [□] |
| | | | | | | | 13 Unknown |
| 1610102 SPANISH BIT PLANTATION SUB | 48:36.0 OnSite Visit | Faith Cotton | TCEQ | UNKNOWN | Minor | NO | |
| 10822001 CITY OF SEADRIFT - SEADRIFT WWTP | 19:47.0 OnSite Visit | Chris Caudle | TCEQ | OPGen | Minor | NO | |
| 290004 CITY OF SEADRIFT | 30:19.0 OnSite Visit | Chris Caudle | TCEQ | GENOK | Minor | NO | would like FEMA assistance in their town. |
| 12261002 SOLHJOU, ALI MOHAMMAD - PIN OAK MHP WWTP | 14:19.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | |
| | | | | | | | |
| | | | | _ | | | Blower needs to be installed. It was observed that the chlorine level was low. The estimated time |
| 14955001 GREATWOOD HOSPITALITY INC - US RV PARK WWTP | 03:53.0 OnSite Visit | Nichole Batista Nunes | • | Рор | None | NO | frame to restore system/facility to "fully operational" status was 1 week. |
| 13892001 TOWN OF BAYSIDE - BAYSIDE WATER RECLAMATION FACILITY | 33:29.0 OnSite Visit | Eric Lindgren | TCEQ | OPGen | Minor | NO | |
| 1010945 REED ESTATES WATER SYSTEM | 56:11.0 OnSite Visit | Nicole Reed | TCEQ | OUT | | UNKNOWN | Unable to access, no damage from outside. |
| | | | | | | | The facility was brought down for maintenance prior to the storm for cleaning. The facility did not |
| 5091000 MULTI-CHEM GROUP | 41:24.0 OnSite Visit | Corey Burke | TCEQ | ОК | None | NO | loose power during the event. |
| 2350042 ARENOSA CREEK ESTATES | 08:36.0 OnSite Visit | Blas Rizzo | TCEQ | INOP | None | NO | residents evacuated and are returning; however, no power or water is available. |
| 2050002 CITY OF INGLESIDE | 10:12.0 OnSite Visit | Eric Lindgren | TCEQ | GENOK | Minor | NO | |
| | | | | | | | District was under water. Manholes were under water. It is unknown if an overflow occured. |
| 11863001 HARRIS COUNTY MUD 150 - HARRIS COUNTY MUD 150 WWTP | 45:44.0 OnSite Visit | Dustin Roberts | TCEQ | ОК | None | NO | Chemicals did not run out, as they had received a delivery. |
| | | | | | | | 5. Blowers are out. Will be fixed on 9/3/2017. 2 |
| | | | | | | | 10. OKC as of 9/3/2017. 2 |
| | | | | | | | Provided the gauges are functioning, there is Chlorine by the bell press. However, there is a |
| 10978001 RIVER PLANTATION MUD - RIVER PLANTATION MUD WWTP | 37:50.0 OnSite Visit | Nichole Batista Nunes | TCEQ | Рор | Minor | NO | chance they might not have chlorine. Partially operational and on the grid. |
| 2350005 BRENTWOOD SUBDIVISION | 32:50.0 OnSite Visit | Blas Rizzo | TCEQ | GENLP | None | NO | BWN issued, facility has no power but has water. |
| 2330003 BREINT WOOD 30BDIVISION | 32.30.0 OHSIC VISIC | BI03 11/220 | TCLQ | GENE | None | 110 | Still on generator; will be for a while. Has fuel delivered as needed. Other than being on |
| 11078001 CITY OF VICTORIA - VICTORIA REGIONAL WWTP | 44:26.0 OnSite Visit | Ericlindaron | TCEQ | OPGen | | | |
| | | Eric Lindgren | | | Mana | NO | generators, facility is fully operational |
| 1011781 HARRIS COUNTY UD 14 | 35:15.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Chlorine Gas - 8 week supply |
| 1012071 NORTHWEST HARRIS COUNTY MUD 24 | 20:00.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | |
| 11450001 CITY OF BEASLEY - CITY OF BEASLEY WWTP | 30:56.0 OnSite Visit | Nichole Batista Nunes | | OK | None | NO | |
| 13483001 HARRIS COUNTY MUD 344 - HARRIS COUNTY MUD 344 WWTP | 31:46.0 OnSite Visit | Dustin Roberts | TCEQ | OK | None | NO | |
| | | | | | | | The facility is a sandblasting facility that uses its permit to discharge filtered water from the |
| | | | | | | | sandblasting activity. No sandblasting is occuring as the facility lacks power, but the treatment |
| 5162000 MILE 533 MARINE WAYS | 49:26.0 OnSite Visit | Corey Burke | TCEQ | ОК | None | | system was not damaged. |
| | | | | | | | system seems to have imtermittent water; however, no one was available to verify this. elevated |
| 2050015 CITY OF ARANSAS PASS | 31:14.0 OnSite Visit | Blas Rizzo | TCEQ | INOP | Severe | YES | storage tank is destroyed and the City only has partial power. |
| | | | | | | | 4. Electrical power status - unknown |
| | | | | | | | 10. BWN issue - Unknown [®] |
| | | | | | | | 16. Follow up - 2 Days? |
| | | | | | | | 73 |
| | | | | | | | 73 |
| 1700490 WESTMONT MOBILE HOME COMMUNITY | 39:19.0 OnSite Visit | Destiny Geppert | TCEQ | SITE | None | NO | ш |
| 1700490 WESTWONT WOBILE HOWE COMMONTH | 39.19.0 Offsite visit | bestilly deppert | TCEQ | SILE | None | NO | |
| AZOCCCZ CAN IO LITUITIES | 46.00.0.0.60.40.47.4 | Bastia Casasat | T050 | 014 | News | NO | Not running low on chemicals. 2 |
| 1700327 SAN JO UTILITIES | 46:09.0 OnSite Visit | Destiny Geppert | TCEQ | OK | None | NO | Does not need assistance in getting chemicals. |
| 12070002 ALDINE ISD - ALDINE ISD CHRISMAN ROAD WTP | 40:02.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Fully operational. No follow up required. |
| 14482001 MONTGOMERY COUNTY MUD 83 - MONTGOMERY COUNTY MUD 83 WWTP | 45:00.0 OnSite Visit | Lythia Metzmeier | TCEQ | OK | None | NO | 26528 Triverton |
| 1700781 CROWN RANCH SUBDIVISION | 01:52.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | *Chlorine gas |
| 1011032 NORTHWEST PINES MOBILE HOME COMMUNITY | 50:52.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Collapsed Chlorine room due to rot. |
| 1010192 PARKLAND ESTATES | 10:47.0 OnSite Visit | Nicole Reed | TCEQ | OK | None | NO | |
| | | | | | | | Follow up ASAP® |
| | | | | | | | BWN should be issued within 24 Hours? |
| 1700488 PATTON LAKE CLUB | 03:16.0 OnSite Visit | Josephine Garcia | TCEQ | LP/LT | Medium | YES | Estimated time frame to restore system - 24Hours |
| | | | | | | | Flooded lower end, much of area flooded. 2 |
| | | | | | | | One onsite lift pump operating out of four. 2 |
| | | | | | | | 6. Unknown 🛽 |
| 10495142 CITY OF HOUSTON - KINGWOOD WEST WWTP | 20:49.0 OnSite Visit | Lythia Metzmeier | TCEQ | ОК | Minor | YES | 11. Unknown how much |
| | | _, | . 524 | | | . =0 | |
| | | | | | | | facility lost partial power to water plant and needs water to run through wwtp. facility has been |
| 14951001 THE DEVEREUX FOUNDATION - DEVEREUX FOUNDATION WWTP | 07:10.0 OnSite Visit | Blas Rizzo | TCEQ | Pop | Minor | NO | evacuated. facility hopes to have power back and water restored within 12 hours. |
| 450022 BARTEN WSC | 45:55.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Hypochlorination |
| 14921002 NGUYEN, CHUONG ANH; BUI, HOA KHUONG - SOUTHGATE WWTP | 20:43.0 OnSite Visit | | EPA | OK | None | | Last date onsite is unknown. |
| | | Rudy Molina | | | | NO | Last date offsite is unknown. |
| 14277001 SOLHJOU, ALI MOHAMMAD - ALDINE OAKS MOBILE HOME COMMUNITY WWTP | 47:28.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | |
| 1700503 PATTON VILLAGE EAST WATER SYSTEM | 20:50.0 OnSite Visit | Josephine Garcia | TCEQ | SITE | Minor | YES | 16. Follow up ASAP |
| 200411 CITY OF PEARLAND MUD 1 | 46:06.0 OnSite Visit | Miguel Moreno | EPA | OK | None | NO | 16 Two Days follow up |
| 12414001 STONETOWN WOODGATE LLC - WOODGATE MOBILE HOME VILLAGE | 45:40.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | Last onsite date? - Unknown. |
| 1013213 HARRIS COUNTY MUD 383 | 03:05.0 OnSite Visit | Amy Camacho | EPA | OK | None | NO | Info provided via spreadsheet. |
| 450087 ALLEYTON WATER SYSTEM | 40:18.0 OnSite Visit | Kathleen Campbell | TCEQ | UNKNOWN | | UNKNOWN | Chlorine Gas |
| 200158 JOHNSONS WATER SERVICE | 00:07.0 OnSite Visit | Miguel A Moreno | EPA | OK | None | NO | |
| 15328001 FOSTER TIMBER LTD - FOSTER TIMBER WWTP | 50:44.0 OnSite Visit | Rudy Molina | EPA | OK | None | | Facility has not been met yet. |
| | | | | | | | 16. Other - Out of service [™] |
| | | | | | | | 17. Should not be using well, system is in disarray, Appeared to be none to little damage from |
| 1700113 SWEETGUM FOREST | 17:05.0 OnSite Visit | Kathleen Campbell | TCEQ | ОК | None | NO | storm, no contact with operators. |
| 450004 CITY OF WEIMAR | 57:19.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Chlorine Gas |
| | | 2230 | · | | - · · · - | - | |
| | | | | | | | 8. Is the collection system fully operations? No- it is partially operational. 2 |
| | | | | | | | 9. If collection system is not fully operational, why?- The system needs a visual alarm, SSO |
| | | | | | | | occurred. 2 |
| | | | | | | | 11. Did the facility experience overflows in the collection system? 1 lift station is located off-site. 2 |
| 13632001 MEADOWLAND UTILITY CORPORATION - MEADOWLAND UTILITY WWTP | 23:54.0 OnSite Visit | Kayla Ayala | TCEQ | ОК | None | NO | The POC was last on site 9/3/2017. |
| 19092001 WEADOWEAND OTHER COM CHARION - WEADOWLAND UTLETT WWWTF | 23.34.0 Offsite Visit | Nayla Ayala | ICLQ | OK | NONE | NO | THE TOE Was last on site 3/3/2017. |

Fencing? 4. Unknown? 10. Unknown?

| 2229000 IGLOO KATY FACILITY | 12:54.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | | | Facility not built yet. |
|---|-----------------------|-----------------------|------|----------|---------------|----------------|---|
| | | | | | | | City's SCADA system was damaged; however, pumps are run manually with generators. 9/8/17 |
| 40002 CITY OF ROCKPORT | 37:06.0 OnSite Visit | Blas Rizzo | TCEQ | GENLP | Minor | NO | eta for full restoration. |
| | | | | | | | Liberty Well Site Collapsed |
| | | | | | | | Lost power for about 3 hours |
| 200008 CITY OF PEARLAND | 45:04.0 OnSite Visit | Miguel A. Moreno | EPA | OK | Minor | YES | Chemicals OK |
| | | | | | | | Not running low on chemicals |
| 1700115 MONTGOMERY COUNTY UD 2 | 28:23.0 OnSite Visit | Destiny Winning | TCEQ | OK | None | NO | Does not need assistance in getting chemicals. |
| | | | | | | | 4. electrical power status - Unknown 2 |
| | | | | | | | 10. BWN issue - Unknown [□] |
| 1700426 WOOD ACRES MHP | 17:46.0 OnSite Visit | Destiny Geppert | TCEQ | SITE | None | NO | |
| 10422001 CITY OF INGLESIDE - INGLESIDE WWTP | 10:19.0 OnSite Visit | Karla Trevino | TCEQ | Pop | Minor | NO | |
| 1700507 PINEHURST DECKER PRAIRIE WSC | 50:21.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | *Chlorine gas |
| 14536001 EAST MONTGOMERY COUNTY MUD 4 - MARE BRANCH WWTP | 00:49.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | No special needs for this facility. |
| | | | | | | | 9. No customer complaints⊡ |
| | | | | | | | 2nd POC - Ella Brown - 281-344-77102 |
| | | | | | | | Sanitary seal questionable? |
| | | | | | | | Water Level reaches above bottom of casing but unknown if seal is in place. 2 |
| 790185 BROWNS MOBILE HOME PARK | 23:35.0 OnSite Visit | Meaghan Bresnahan | EPA | OK | Minor | NO | Chemicals - Fine on chlorine, No chemical spills, no major issues. |
| | | | | | | | Unable to see the facility. The POC is not the facility owner anymore. The condition of the |
| | | | | | | | damage is unknown. August 28, 5 to 7 days of not having access. A mandatory evacuation. A |
| | | | | | | | drainage ditch must be crossed to access the facility. There is only 1 collection system at the plant |
| | | | | | | | onsite. During the site visit, the plant was not accessible. An apex pump was onsite. It appeared |
| 12113001 ORBIT SYSTEMS INC - BEECHWOOD WWTP | 25:02.0 OnSite Visit | Jack Coleman | TCEQ | NonOp | | UNKNOWN | to be pumping water from plant. |
| 1700039 LAZY RIVER IMPROVEMENT DISTRICT | 11:08.0 OnSite Visit | Nicole Reed | TCEQ | OK | Minor | YES | Gas chlorine, good on chemicals, two weeks. |
| 1610016 MATAGORDA COUNTY WCID 2 | 47:27.0 OnSite Visit | Faith Cotton | TCEQ | SITE | | UNKNOWN | Unknown information, No access due to bridge closed. |
| | | | | | | | There is a generator on site but can't access site, looking through locked fence. Loud hum coming |
| EASTWOOD HILLS MOBILE HOME PARK LIMITED PARTNERSHI - EASTWOOD HILLS SUBDIVISION | | | | | | | from facility. 2 |
| 14979001 WWTP | 05:07.0 OnSite Visit | Lythia Metzmeier | TCEQ | OK | None | NO | 5. Unknown |
| 11200001 DOUGLAS UTILITY COMPANY - FOUNTAINVIEW WWTP | 04:21.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Operational. Major treatment issues. Sludge possibly in receiving stream. |
| | | | | | | | 2. Unknown [□] |
| | | | | | | | 4. Unknown [□] |
| 1610031 OAK HOLLOW SUBDIVISION | 50:18.0 OnSite Visit | Faith Cotton | TCEQ | CLEAR | | UNKNOWN | 11,12,13 - Unknown |
| 12298002 FORT BEND COUNTY MUD 34 - FORT BEND COUNTY MUD 34 WWTP 2 | 15:02.0 OnSite Visit | Nichole Batista Nunes | TCEQ | OK | None | NO | |
| 14414001 242 LLC - WOODLAND LAKE VILLAGE WWTP | 30:54.0 OnSite Visit | Lythia Metzmeier | TCEQ | ОК | | | Facility has not been built yet. |
| 1010737 LAKE HOUSTON STORAGE | 10:19.0 OnSite Visit | Nicole Reed | TCEQ | ОК | None | NO | , |
| 14850001 CITY OF SOUTHSIDE PLACE - CITY OF SOUTHSIDE PLACE WWTP | 15:53.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Fully operational. No followup required. |
| | | 3 | • | | | | Chemical onsite is Sodium Hypochlorite. There is more than 20 gallons left. 2 |
| | | | | | | | The loack to the front gate was open. Clarifier motor was down. Chlorine contact basin was |
| 12849001 YES COMPANIES LLC - RAINTREE ACRES MHP WWTP | 25:30.0 OnSite Visit | Jack Coleman | TCEQ | Рор | None | NO | operating but had a fair amount of solids. |
| 2410015 S P J S T REST HOME | 48:47.0 OnSite Visit | Maria Okpala | EPA | ОК | None | NO | - F |
| 12261001 SOLHJOU, AKRAM - MELROSE MHP WWTP | 27:01.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | |
| | | | | | | | They have bleach on site. |
| 200102 MANVEL ROAD TERRACE SUBDIVISION | 35:38.0 OnSite Visit | Miguel Moreno | EPA | ОК | Minor | NO | Chemicals are good |
| | | gaeerene | | | | | Unable to make contacat with facility representative. Blowers were running and could smell |
| 12631001 HARRIS COUNTY MUD 202 - HARRIS COUNTY MUD 202 WWTP | 20:11.0 OnSite Visit | Dustin Roberts | TCEQ | ОК | None | NO | chlorine. Discharging clear effluent. |
| 12001001 TWWWW COOKET WOOD 202 TWWWW COOKET WOOD 202 WWYT | 20.11.0 0110110 11011 | Bustin Nobel is | 1020 | O.K | None | 110 | Surface Water plant? |
| | | | | | | | Not low on any chemicals? |
| | | | | | | | Expecting LAS shipment in few days. 2 |
| 2360058 TRA HUNTSVILLE REGIONAL WATER SUPPLY | 05:01.0 OnSite Visit | Nicole Reed | TCEQ | ОК | None | NO | All other chemicals good for at least a week. |
| 2500050 THATTOMISTILLE REGIONAL WATER SOLITE | OS.O1.0 Onsite visit | Wiebie Need | TCLQ | OK . | None | 110 | 400 (215) Lakeview well - no fence. |
| 200004 CITY OF CLUTE | 30:37.0 OnSite Visit | Josephine Garcia | TCEQ | SITE | None | UNKNOWN | #3 - Unknown |
| 1700642 WOOD TRACE MUD 1 | 35:55.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | "S SHAROWII |
| 1700777 EMERALD LAKES SUBDIVISION | 05:42.0 OnSite Visit | Destiny Winning | TCEQ | LP/LT | None | NO | 10. BWN issue - Unknown |
| 290050 ENCHANTED HARBOR | 21:25.0 OnSite Visit | Chris Caudle | TCEQ | GENOK | None | NO | 10. DVVIV 1350C OTINIOWIT |
| 14468001 UA HOLDINGS 1994-5 LP - SUNRISE RANCH WWTP | 00:49.0 OnSite Visit | Lythia Metzmeier | TCEQ | OK | None | NO | |
| 12552001 NCI GROUP, INC NCI BUILDING SYSTEMS WWTP | 11:37.0 OnSite Visit | Dustin Roberts | TCEQ | OK OK | None | NO | |
| 10256001 REFUGIO COUNTY WCID 1 - REFUGIO COUNTY WCID 1 WWTP | 35:39.0 OnSite Visit | Eric Lindgren | TCEQ | OPGen | Minor | NO | Will be on generators for a while. Currently getting tanks filled with fuel daily. |
| 10250001 REPOGIO COUNTY WCID 1 - REPOGIO COUNTY WCID 1 WWYP | 55.59.0 Offsite visit | Enc Lindgren | TCEQ | Orden | WIIIIOI | NO | ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,, |
| | | | | | | | Plant was under water and without power for two days. Generator ran out of gas and was |
| | | | | | | | inaccessible. Blower #2 was damaged, approximately 5-10K. Power restored Monday. 4 off-site |
| 44040002 HARRIS COUNTY MUR 440. HARRIS COUNTY MUR 440 MAYER 2 | AF-OF O Origina Visit | Deserting Bally out o | TCFO | 01/ | N. Alica care | LINUXNICOVAVNI | lift stations. Water in the motor starters at 2. Functioning but need repairs. Burned up gate |
| 11818003 HARRIS COUNTY MUD 148 - HARRIS COUNTY MUD 148 WWTP 2 | 15:05.0 OnSite Visit | Dustin Roberts | TCEQ | OK | Minor | UNKNOWN | controller. Adequate chemical supply. |
| 11673001 WOODLOCH MHP LLC - WOODLOCH MHP WWTP | 21:57.0 OnSite Visit | Isaiah Longoria | TCEQ | ОК | None | NO | Fully operational. No follow-up needed. |
| AGGOOGA CITY OF DEFINOIS | 04 50 0 0 00 10 10 10 | | T050 | 05111.5 | | V=0 | Grond Storage Tank has holes on top, currently not using. BWN was verbal and posted on |
| 1960001 CITY OF REFUGIO | 01:50.0 OnSite Visit | Eric Lindgren | TCEQ | GENLP | Medium | YES | Facebook. |
| | | | | | | | Unable to Contact - No working number |
| 4043333 4600047/44 465 44057 5 11045 5 2 577 | 46.04.0.6.00 | A11 1 5 1 | T050 | | | | Unable to locate well site. Output Description: |
| 1012333 ACORN VILLAGE MOBILE HOME PARK | 46:34.0 OnSite Visit | Nicole Reed | TCEQ | UNKNOWN | | UNKNOWN | Information Unknown. |
| | | | | | | | 5. Unknown |
| | | | | | | | 6. Unknown 🛚 |
| | | | | | | | 9. Unknown |
| MONTGOMERY COUNTY MUNICIPAL UTILITY DISTRICT 137 - MONTGOMERY COUNTY MUD 137 | | | | | | | 15. Unknown ² |
| 15157001 WWTP | 14:46.0 OnSite Visit | Nichole Batista Nunes | · | OK | None | UNKNOWN | 16. Unknown |
| 1700652 PINE KNOB SUBDIVISION | 45:03.0 OnSite Visit | Josephine Garcia | EPA | LP/LT | None | NO | 11. BWN issued due to loss of power |
| | | | | | | | |

| | | | | | | | were off. 2 |
|---|--|----------------------------------|-------------|----------|--------|---------|---|
| | | | | | | | 11. Did the facility experience overflows in the collection system?- Pressurized sewer system. 2 |
| 14149001 SP UTILITY COMPANY INC - SAVANNAH PLANTATION WWTP | 40:45.0 OnSite Visit | Kayla Ayala | TCEQ | Рор | Minor | NO | The plant does 10,000 gallons per day. They ave 1 to 2 months of chemical supply on site. |
| | | | | | | | How many days supply do you have left? 80 gallones of bleach (2 weeks worth). 2 |
| 14188001 MANVEL UTILITIES LP - OAK CREST MHP WWTP | 42:12.0 OnSite Visit | Kayla Ayala | TCEQ | OK | None | NO | Operator was last on site on 9/3/2017. |
| | | | | | | | One of the well pumps burned up and is on order, currently using additional well. BWN was |
| 1960004 REFUGIO COUNTY WCID 1 | 53:04.0 OnSite Visit | Eric Lindgren | TCEQ | GENLP | Medium | YES | posted on facebook and flyers handed out. |
| | | | | | | | |
| 40017 COPANO HEIGHTS WATER | 50:48.0 OnSite Visit | Blas Rizzo | TCEQ | GENLP | None | NO | facility experiencing intermittent power and water. water supply is contigent on City of Rockport. |
| | | | | | | | Plant not Accessible due to flooding on CR252 |
| | | | | | | | 3,4, and 5 - Unknown 🛽 |
| 200277 MALLARD LAKE CLUB | 30:30.0 OnSite Visit | Josephine Garcia | TCEQ | SITE | Medium | UNKNOWN | 10, 11, 12, 13 - Unknown. |
| | | | | | | | System is low on caustic. Providing limited water to Aransas Pass, Rockport, and Port A to check |
| 2050011 SAN PATRICIO MWD | 30:16.0 OnSite Visit | Eric Lindgren | TCEQ | GENOK | Minor | NO | for leaks in distribuition system. |
| 12414001 STONETOWN WOODGATE LLC - WOODGATE MOBILE HOME VILLAGE | 28:23.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | Last date onsite is unknown. |
| | | | | | | | 3. Unknown. 2 |
| 2360026 GREEN RICH SHORES AND STERLING ISLAND SU | 46:58.0 OnSite Visit | Nicole Reed | TCEQ | OK | None | UNKNOWN | |
| 2360027 BELL & FORD MARINA CAMPGROUND | 07:18.0 OnSite Visit | Nicole Reed | TCEQ | OK | None | NO | They are not running low on any chemicals |
| | | | | | | | The collection system does not have many generators or pumps to move wastewater from |
| | | | | | | | liftstations. No water is being sent to the collection system/WWTP because WTP/distribution |
| 10054001 CITY OF ROCKPORT - CITY OF ROCKPORT WWTP | 45:02.0 OnSite Visit | Jay Halepeska | TCEQ | OPGen | Minor | NO | system is still down. |
| 1700029 LAKEWOOD COLONY | 32:00.0 OnSite Visit | Josephine Garcia | TCEQ | OK | Minor | NO | |
| 290001 CITY OF POINT COMFORT | 57:35.0 OnSite Visit | Chris Caudle | TCEQ | OK | Minor | NO | |
| 13564001 HARRIS COUNTY MUD 304 - HARRIS COUNTY MUD WWTP | 50:37.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Fully operational. No follow up needed. |
| 14987001 JMH HOMES-HOUSTON LLC - HERMANN OAKS MHP WWTP | 10:05.0 OnSite Visit | Dustin Roberts | TCEQ | OK | None | NO | Blowers running. Small amount of sludge in receiving stream. |
| 14064001 STAFFORD MOBILE HOME PARK INC - STAFFORD MHP WWTP | 20:54.0 OnSite Visit | Nichole Batista Nunes | TCEQ | OK | None | UNKNOWN | Was unable to see the facility. It is entirely enclosed. Operator could not meet us. |
| | | | | | | | Contacted 979-798-0335, a man answered who was not connected with the WWTF. Gav the name |
| | | | | | | | Steve Galloway as the new site superintendent for this WWTF. Called Scott Williams phone |
| 14893001 COLUMBIA-BRAZORIA ISD - WILD PEACH ELEMENTARY WWTP | 15:08.0 OnSite Visit | Kayla Ayala | TCEQ | OUT | None | NO | number, was disconnected line. no discharge was observed. |
| | | | | | | | 4. Electrical power status - unknown? |
| 2360069 WALKER COUNTY SUD D | 00:47.0 OnSite Visit | Destiny Geppert | TCEQ | UNKNOWN | Minor | NO | 10. BWN issue - unknown |
| | | | | | | | Facility is low on chemicals. Chemicals needed include Chlorine, bleach. Approximately 75% of |
| | | | | | | | chemical supply remains, 4 to 6 weeks worth. No issues were noted during the site visit at the |
| 12420001 ORBIT SYSTEMS INC - ANGLE ACRES WWTP | 26:54.0 OnSite Visit | Jack Coleman | TCEQ | OK | None | NO | point of the site inspection. |
| 1011252 FOREST HILLS MUD | 55:22.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | |
| | | | | | | | |
| 14250001 W-INDUSTRIES OF TEXAS LLC; W-INDUSTRIES LIMITED LP - W-INDUSTRIES OF TEXAS WWTP | 02:52.0 OnSite Visit | Dustin Roberts | TCEQ | OK | None | NO | |
| | | | | | | | Contact person: Patrick C. King (512) 894-3322. Left message with person (Answering Service). |
| 260007 CADE LAKES WSC | 39:09.0 OnSite Visit | Omar T. Martinez | EPA | UNKNOWN | None | NO | Status: Unknown |
| | | | | | | | system operational, however not able to provide water to customers due to damage within in the |
| | | | | | | | collection system at individual meters. Updated code to GENLP to reflect BWN and generally |
| 40002 CITY OF ROCKPORT | 45:21.0 OnSite Visit | Eric Lindgren | TCEQ | GENLP | Minor | NO | operating under generator power, lost power. |
| | | | | | | | Could not locate - No facility/interconnect visible at address supplied by bww - distribution |
| 1700554 MONTGOMERY COUNTY MUD 67 | 05:18.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | | UNKNOWN | system only |
| | | | | | | | facility has intermittent water useage. facility has no power and no physical facilities and water |
| 40029 COPANO RIDGE SUBDIVISION | 46:12.0 OnSite Visit | Blas Rizzo | TCEQ | LP/LT | None | NO | service is contingent on City of Rockport production. |
| 13774001 SOUTH CENTRAL CALHOUN COUNTY WCID 1 - SCCCWCID 1 | 45:04.0 OnSite Visit | Chris Caudle | TCEQ | OPGen | Minor | NO | system had a brief bypass, not currently bypassing. |
| | | | | | | | The facility is pumping out lift stations and pumping into the aeration basins. No power to the |
| 10513002 VICTORIA COUNTY WCID 1 - VICTORIA COUNTY WCID 1 WWTP | 40:03.0 OnSite Visit | Karla Treviño | TCEQ | Pop | None | NO | plant at this time. Operator is adding HTH to the basin for minor treatment. |
| 1700279 CARRIAGE HILLS | 37:59.0 OnSite Visit | Nicole Reed | TCEQ | OUT | | | Information Unknown |
| | | | | | | | Raw well water is being supplied to 75% of distribution system. Raw water is bheing supplied to |
| 40018 ARANSAS BAY UTILITIES | 50:06.0 OnSite Visit | Eric Lindren | TCEQ | LP/LT | Minor | NO | Aransas County MUD No.1. Broken mains in system. |
| | | | | | | | 16. ASAP® |
| | | | | | | | Elmwood St 40 psi |
| | | | | | | | 0.00 mg/L free chlorine? |
| | | | | | | | Resident stated flooded up to porch (3ft) |
| 200440 BINE COLONY MORUE HOME BARY | 20:20.0.0.0 | January 10 and 10 | TCFC | 15/17 | N1= | NO | Well was likely flooded Not ours if BNAN was issued. |
| 200419 PINE COLONY MOBILE HOME PARK | 36:26.0 OnSite Visit | Josephine Garcia | TCEQ | LP/LT | None | NO | Not sure if BWN was issued. |
| 1700783 PEACH CREEK PLANTATION WATER SYSTEM | 00:02.0 OnSite Visit | Josephine | TCEQ | OK | None | NO | |
| 12882001 SOLHJOU, BAHRAM - ROSEWOOD MHP WWTP | 00:58.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | No chemicals are needed for the plant to be operational. |
| 14963001 BEACON ESTATES WSC - BEACON ESTATES WWTP | 48:13.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | unite and collection anatom fully an autional, assessment as section as a section of the firstly as a |
| 422C2004 BLOCECE OF WICTORIA IN TEVAS. CRIDITUAL BENEVAL CENTER WANTE | 47.46.0.0.60.10.10.11 | Dia Di | T050 | D | None | NO | wwtp and collection system fully operational; owever, no water or power at the facility. eta for |
| 13362001 DIOCESE OF VICTORIA IN TEXAS - SPIRITUAL RENEWAL CENTER WWTP 1011796 WOODGATE MOBILE HOME VILLAGE | 47:46.0 OnSite Visit | Blas Rizzo | TCEQ | Pop | None | NO | both is 9/5. |
| | 30:14.0 OnSite Visit | Kathleen Campbell | TCEQ | OK | None | NO | Hypochlorine - 2 barrels - 3 month supply |
| 12934001 RANKIN ROAD WEST MUD - RANKIN ROAD WEST MUD WWTP | 17:04.0 OnSite Visit | Isaiah Longoria | TCEQ | OK | None | NO | Fully operational. No follow-up required. |
| | | | | | | | Digestor Foundation has eroded. 2 |
| | | | | | | | High water mark is approximately 6.5 ft, 234 conn. 2 |
| 11580001 TOWN OF WOODLOCK TOWN OF WOODLOCK WANTE | 10.EE 0 005ita Visit | Nichola Batista Numan | TCEO | Don | Sovere | VEC | Lift stations damaged on Wednesday/Thursday. Piver paks under water approximately 4-5 days |
| 11580001 TOWN OF WOODLOCH - TOWN OF WOODLOCH WWTP | 19:56.0 OnSite Visit | Nichole Batista Nunes | * | Pop | Severe | YES | River oaks under water approximately 4-5 days. |
| 11624001 ARANSAS COUNTY MUD 1 - ARANSAS COUNTY MUD 1 WWTP | 40:12.0 OnSite Visit | Karla Trevino | TCEQ | OPGen | Minor | YES | When were you lost on site? 0/4/47 |
| 13767001 FATIMA FAMILY VILLAGE INC - FATIMA FAMILY VILLAGE WWTP | 40:24.0 OnSite Visit | Rudy Molina | EPA | OK | None | NO | When were you last on site? 9/1/17. |
| 2350036 COLETO WATER | 30:59.0 OnSite Visit | Karla Treviño | TCEQ | INOP | | | No flow, restaurant is closed. Not affected. Last on-site Friday, on-site management. They have |
| 12020001 DIEDEL ANTHONY IOHNI HICKORY HOLLOW/ININ WAYATE | 20.10 0 Onsite Whit | Ductio Bohorto | TCEO | OV | None | NO | , |
| 13939001 RIEDEL, ANTHONY JOHN - HICKORY HOLLOW INN WWTP 15082001 GREENBAY REAL ESTATE INVESTMENT LP - CHANEY WWTP | 30:19.0 OnSite Visit | Dustin Roberts | TCEQ | OK | None | NO | plenty of tablets. |
| 15082001 GREENBAY REAL ESTATE INVESTMENT LP - CHANEY WWTP 1010279 MEMORIAL HILLS UTILITY DISTRICT | 07:07.0 OnSite Visit 45:37.0 OnSite Visit | Rudy Molina Kathleen Campbell | EPA TCEQ | OK OK | None | NO | Facility has not been built yet. |
| 10102/3 WILIWONIAL THELS OTHERT DISTRICT | 45.57.0 Olisite Visit | кайшеен сашроен | ICEU | UN | NOTIE | NO | Chlorine Gas supply unknown |
| | | | | | | | |

Fences were knocked over and down in the eastern part of the property. Aevation basin blowers

| 10742001 AQUA UTILITIES INC - BRENTWOOD MANOR SUBDIVISION | 40:15.0 OnSite Visit | Blas Rizzo | TCEQ | OPGen | None | NO | |
|--|--|----------------------------------|--------------|--------------|--------------|----------------|--|
| 422.42224 18.5 14.4 TER COMPANY 1.5 A AMBLE 1.5 A 5 CARRENG MANTE | 46.40.0.0.60. \(\text{V''} \) | | T050 | 01/ | | | Could hear blower running. System has two backup gas cylinders. No assistance is needed per the |
| 12342001 J&S WATER COMPANY LLC - MAPLE LEAF GARDENS WWTP 12466001 OCEANEERING INTERNATIONAL INC - OCEANEERING INTERNATIONAL WWTP | 16:43.0 OnSite Visit 21:20.0 OnSite Visit | Dustin Roberts Dustin Roberts | TCEQ TCEQ | OK OK | None None | NO NO | operator. Last site visit was 9/3/2017. |
| 12466001 OCEANEERING INTERNATIONAL INC - OCEANEERING INTERNATIONAL WWTP | 21:20.0 Onsite visit | Dustin Roberts | ICEQ | UK | None | NO | 16. 2 DAY Followup? |
| 200036 ROSHARON TOWNSHIP | 45:50.0 OnSite Visit | Miguel Moreno | EPA | ОК | None | NO | 10. 2 DAT FOROWAPE |
| | | - | | | | | 2. Unknown [®] |
| | | | | | | | 3. Unknown [□] |
| | | | | | | | 4. Unknown [□] |
| | | | | | | | 10. Unknown® |
| | | | | | | | 11,12,13,14 - Unknown 2 |
| 1610033 TIDEWATER OAKS SUBDIVISION | 08:43.0 OnSite Visit | Faith Cotton | TCEQ | CLEAR | | UNKNOWN | Looks Good |
| 14586001 MONTGOMERY COUNTY MUNCIPAL UTILITY DISTRICT 105 - ER WOODSON WWTP | 15:58.0 OnSite Visit | Nichole Batista Nunes | TCEQ | UNKNOWN | None | NO | 10. Current collection system operational status is uknown. |
| 5097000 VOESTALPINE TEXAS | 45:41.0 OnSite Visit | Caray Burka | TCEQ | OK | None | NO | The facility was brought down for maintenance prior to the storm for cleaning. The facility did not |
| 5097000 VOESTALPINE TEXAS | 45:41.0 Onsite visit | Corey Burke | TCEQ | OK | None | NO | loose power during this event Chlorine gas? |
| 450001 CITY OF COLUMBUS | 06:05.0 OnSite Visit | Kathleen Campbell | TCEQ | ОК | None | NO | - Poly phosphate |
| 4997000 GOYA FOODS | 38:51.0 OnSite Visit | Ratificen campben | rceq | OK | None | 110 | Facility has not been built yet. |
| 1337666 66 11176625 | SOISTIO CHOICE VISIC | | | | | | radincy has not been bank yet. |
| 40003 COPANO COVE SUBDIVISION | 55:44.0 OnSite Visit | Blas Rizzo | TCEQ | INOP | None | NO | facility experiencing intermittent water. contingent on City of Rockport for water supply. |
| 15040001 TRINITY @ WINDFERN LLC - WINDFERN MHP WWTP | 58:31.0 OnSite Visit | Dustin Roberts | TCEQ | OUT | None | NO | Blower was running. Unable to acccess plant and see outfall. Return and influent was flowing. |
| 40015 HOLIDAY BEACH WSC | 20:53.0 OnSite Visit | Eric Lindgren | TCEQ | LP/LT | Severe | YES | Broken mains all over distribution system. Diesel shortage for generator. |
| | | | | | | | The facility does not have power. The system only serves 11 customers. The customers are not |
| 2350009 THE ESTATES OF SANDY HILLS | 15:40.0 OnSite Visit | Karla Treviño | TCEQ | INOP | Minor | | residing in the area due to damage to trailers. |
| | | | | | | | Reverse osmosis treatment offline until leaks fixed; redundant booster pump lost, pump has ~9 |
| | | | | | | | week lead time; chlorine supply limited; need distrubution pipe clamps and fittings; diesel |
| | | | | | | | supplier for generator is unreliable; financial concerns for funding the repairs; of the 760 |
| 40015 HOLIDAY BEACH WSC | 54:23.0 OnSite Visit | Ian Taylor, TxSG | TCEQ | GENLP | Medium | NO | connections, only 300 might be left once customers abandon lost homes |
| 1012166 MILLER MHP | 48:35.0 OnSite Visit | Nicole Reed | TCEQ | ОК | None | NO | |
| | | | | | | | 8. Unknown if system has elevated storage. |
| | | | | | | | Not running low on chemicals |
| 1700207 TEXAS NATIONAL MUD | 21:16.0 OnSite Visit | Destiny Winning | TCEQ | OK | None | NO | Does not need assistance getting chemicals |
| 400.40 ADAMSAS SOUNTWAND 4 | 40.05.0.0.5015 | | T050 | | | | System is being provided with raw well water from Aransas Bay Utilities. Roof torn off of main |
| 40042 ARANSAS COUNTY MUD 1 | 40:06.0 OnSite Visit | Eric Lindgren | TCEQ | LP/LT | Medium | NO | building. |
| 12743001 VICTORIA COUNTY WATER CONTROL AND IMPROVEMENT DIST - PLACEDO WWTP 2350001 VICTORIA COUNTY WCID 1 | 05:30.0 OnSite Visit 45:49.0 OnSite Visit | Karla Treviño Karla Treviño | TCEQ TCEQ | OUT GENLP | None | | Unknown if samples have been taken for BacTs |
| 2330001 VICTORIA COUNTY WCID 1 | 45.45.0 Offsite visit | Karia Hevillo | TCEQ | GENLP | None | | 16. ASAP® |
| | | | | | | | Free chlorines - 0.0 2 |
| | | | | | | | Pressure - 48psi 2 |
| | | | | | | | Checked at one of three trailers |
| | | | | | | | Resident stated water did not get higher than the well but hard to determine. |
| | | | | | | | Does not know conditions of water system under mandatory evacuation. 2 |
| 200134 COUNTRYSIDE MOBILE HOME PARK | 06:51.0 OnSite Visit | Josephine Garcia | TCEQ | SITE | Medium | UNKNOWN | |
| | | | | | | | 4. Electrical power status - NAD |
| | | | | | | | 6. Purchasing from 17006292 |
| 1700114 PIONEER TRAILS SUBDIVISION | 06:47.0 OnSite Visit | Josephine Garcia | TCEQ | OK | None | NO | |
| 11574001 SPRING CREEK UD - SPRING CREEK UD WWTP | 45:19.0 OnSite Visit | Lythia Metzmeier | TCEQ | OK | None | NO | 10. Unknown |
| 1960006 CITY OF AUSTWELL 1010252 URBAN ACRES SUBDIVISION | 42:13.0 OnSite Visit 49:33.0 OnSite Visit | Eric Lindgren Nicole Reed | TCEQ TCEQ | GENLP OUT | Medium | YES UNKNOWN | Locked site |
| 1010252 ONDAN ACKES SOBDIVISION | 49.33.0 Offsite visit | Micole Reed | relu | 001 | | ONKINOVIN | Locked Site |
| | | | | | | | VFD at the raw water intake is down, currently using other pump onsite to pump (non VFD). 2 |
| | | | | | | | Clayton Nicolardi (TCEQ-TOPS team) and Eric Lindgren (TCEQ-Corpus Christi Region Office) have |
| | | | | | | | been onsite since 9/1 working with plant staff to optimize the plant to normal operation conditions. Water is being supplied to distribution (BWN in place). BWN was done either 8/26 or |
| 2350002 CITY OF VICTORIA | 11:24.0 OnSite Visit | Eric Lindgren | TCEQ | LP/LT | Minor | | 8/27. |
| | TILE NO ONSITE VISIT | 2.10 Elliagiell | | / | | | 4. Unknown⊡ |
| | | | | | | | 10. BWN unknown |
| | | - - . | TCEQ | UNKNOWN | Minor | NO | |
| 2360074 WALKER COUNTY SUD F | 25:24.0 OnSite Visit | Destiny Geppert | TCEQ | CINKINOVVIN | IVIIIIOI | | |
| 2360074 WALKER COUNTY SUD F 10521002 CITY OF ARANSAS PASS - ARANSAS PASS WWTP | 25:24.0 OnSite Visit 45:50.0 OnSite Visit | Destiny Geppert Karla Trevino | TCEQ | OPGen | Minor | NO | The City is not sending water to residents, so there is minimal to no flow at the WWTP. |
| | | , , , | | | | NO | The City is not sending water to residents, so there is minimal to no flow at the WWTP. |
| 10521002 CITY OF ARANSAS PASS - ARANSAS PASS WWTP | 45:50.0 OnSite Visit | Karla Trevino | TCEQ | OPGen | Minor | | The City is not sending water to residents, so there is minimal to no flow at the WWTP. Blowers were running. |